

RAJIV GANDHI INSTITUTE OF VETERINARY EDUCATION AND RESEARCH
Kurumbapet, Puducherry-9
DEPARTMENT OF VETERINARY PUBLIC HEALTH AND EPIDEMIOLOGY
No.29 - 205 /VPE/RIVER/ Dt. 12.08.2026

WATER TESTING REPORT

Ref: Letter from Oxford International School, Mannadipet, Thirukkanur Road, Puducherry-605501, Telephone no. 9789495695

Sample: One water sample (one liter) received on 10.08.2026.

Test performed

pH (Normal: 6.8 to 8.5)	:	7.2
Hardness (MPL- 150mg/lit)	:	60mg/L
Chloride (MPL - 250mg/lit)	:	50mg/L
Coliforms (should be absent)	:	Nil
E. coli (should be absent)	:	Nil

REMARKS

- pH is within normal range
- Hardness and chloride are within normal range.
- Microbiological quality of the water sample is good
- The water sample is suitable for drinking based on the tested parameters only.

Receipt No. 18667 , Rs. 250/-, Dated 10.08.2026

**This result should not be used for judicial or legal purpose.*

V. Bhal
12/08/26

PROFESSOR & HEAD
Dept. of Veterinary Public Health & Epidemiology
Rajiv Gandhi Institute of Veterinary
Education & Research
Kurumbapet, Puducherry-605 009.